



# License No. 75810 to mark a commodity with the Standards Mark

The Standards Institution of Israel (SII), in accordance with the powers vested in it by article 11(b) of the Standards law 1953, hereby grants permission to:

## **DOMOFERM EXPORT GMBH.**

Sonnenweg 1 2230, Ganserndorf Austria

to place the Standards Mark on the commodities covered by the standard:  
**Fire Door And Smoke Door Assemblies: Swinging Fire Doors**

(list of types attached)

**These commodities are produced in conformity with the requirements of the  
Israel Standard No. 1212 Part 1 Edition May 2003 Amendment 1, 2, 3, 4, 5, 6**

This license has been granted subject to the terms of the Standards Regulation (standard mark and supervision sign) 1982, and the terms that the License Committee has determined, which constitute an integral part of this license. This license does not detract from any obligation, or other order, imposed by law on the abovementioned commodities

This certificate remains the property of SII. Its continued validity may be verified via scanning the barcode or via the SII website [www.sii.org.il](http://www.sii.org.il).

**This license is valid until 31/12/2023**

Date of License : 01/01/2023



R.N

Dr. Gilad Golub  
CEO



The standards Institution of Israel  
42 Chaim Levanon St,  
Tel-Aviv 6997701



## Annex A: License No. 75810

**Factory: DOMOFERM EXPORT GMBH.**

**Commodities: Fire Door And Smoke Door Assemblies: Swinging Fire Doors**

### Models:

1. Double Wing Fire Door(With/ Without Windows),Model US632D, Designation: Fire Door ½ Hour (½/ ½ / ½).  
Maximum frame dimensions:height 2665 mm,width 2630  
Maximum dimensions of active wing: height 2600 mm,  
width 1250 mm. Window 360x1160 mm.
2. Single Wing Fire Door(With/ Without Windows),Model US631D, Designation: Fire Door ½ Hour (½/ ½ / ½).  
Maximum frame dimensions:height 2665 mm,width 2630  
Maximum dimensions of active wing: height 2600 mm,  
width 1250 mm. Window 360x1160 mm.

**This license is valid until 31/12/2023**

Date of License : 01/01/2023



R.N

Dr. Gilad Golub  
CEO



The standards Institution of Israel  
42 Chaim Levanon St,  
Tel-Aviv 6997701

# היתר מספר 75810 לסמן מצרך בתו תקן

מכון התקנים הישראלי, בתוקף סמכותו לפי סעיף 11(ב) לחוק התקנים התשי"ג 1953 מעניק בזה ל:

## דומופרם - DOMOFERM EXPORT GMBH

Sonnenweg 1 2230, Ganserndorf Austria

את הרשות לסמן בתו תקן את המצרכים שחל עליהם התקן שלהלן:  
**מכללי דלתות אש ומכללי דלתות עשן: דלתות אש סובבות**

רשימת דגמים מצורפת

מצרכים אלה מיוצרים לפי דרישות התקן הישראלי ת"י 1212 חלק 1 מהדורה מאי 2003 ג"ת 6, 5, 4, 3, 2, 1

היתר זה ניתן בכפיפות לתנאים שבתקנות התקנים (תו-תקן וסימן השגחה), התשמ"ב 1982 ולתנאים שהחליטה עליהם ועדת ההיתרים, המהווים חלק בלתי נפרד מהיתר זה. היתר זה אינו גורע מכל חובה, או הוראה אחרת, המוטלת על פי דין על המצרכים הנ"ל. ההיתר הוא רכוש מת"י. לברור תוקף ההיתר ניתן לסרוק את הברקוד, או להיכנס לאתר מכון התקנים הישראלי [www.sii.org.il](http://www.sii.org.il)

**תוקף ההיתר עד יום 31/12/2023**

  
ד"ר גלעד גולוב  
מנכ"ל



פ.ח.

תחילת תוקף היתר: 01/01/2023

עמוד 1 מתוך 2



  
מכון התקנים הישראלי  
רחוב חיים לבנון 42,  
תל-אביב 6997701

# נספח א' להיתר: 75810 מפעל: דומופרם - DOMOFERM EXPORT GMBH

**מצרכים:** מכללי דלתות אש ומכללי דלתות עשן: דלתות אש סובבות

**דגמים:**

1. דלת אש דו אגפית (עם/בלי צוהרים) US632D  
שכינוייה 1/2 שעה (1/2, 1/2, 1/2)  
מידות מלבן מירביות: רוחב 2630 מ"מ, גובה 2665 מ"מ  
מידות מירביות אגף פעיל: רוחב 1250 מ"מ, גובה 2600 מ"מ  
מידות צוהר 360X1160 מ"מ
2. דלת אש חד אגפית (עם/בלי צוהרים) US631D,  
שכינוייה 1/2 שעה (1/2, 1/2, 1/2),  
מידות מלבן מירביות: רוחב 2630 מ"מ, גובה 2665 מ"מ,  
מידות מירביות אגף פעיל: רוחב 1250 מ"מ, גובה 2600 מ"מ  
, מידות צוהר: 360X1160 מ"מ



**תוקף ההיתר עד יום 31/12/2023**

  
ד"ר גלעד גולוב  
מנכ"ל



פ.ח.

תחילת תוקף היתר: 01/01/2023

עמוד 2 מתוך 2

